

M10012/27CK-5EU-JT3

APPLICATION and PERFORMANCE SPECIFICATION

Standard - electronic low frequency square wave ballast for 100W metal halide lamps with 120V "tap" for 3 or Description: 4-wire self heating thermal protectors (IDTPs)

- Line Voltage : 120/277vac, +/-10%, 50/60Hz
- Microprocessor controlled
- RoHS Compliant
- Stude Top load avit Mounting type

- · Resonance Start
 - · Active power factor correction
 - · Abnormal operation shutdown circuit: Line voltage must be reset

 Mounting type. 	Sluds - Top lead exit	
*60 Hz data		

Lamp		Volts	Input	Nominal	Power	Ballast	Harmonic	Crest
ANSI Type	#		Watts	Line Amps	Factor	Factor	Total	Factor
	1	120	110 w/o IDTP	0.94	> 95%	1.00	< 8%	<1.5
M/C90		277	107 w/o IDTP	0.42	> 95%	1.00	< 11%	<1.5
M/C140 M/C164	1	120	112 w/IDTP	0.96	> 95%	1.00	< 8%	<1.5
		277	109 w/IDTP	0.43	> 95%	1.00	< 11%	<1.5

Ballast Order Code:

Performance:

- Meets ANSI Standard C82.14-2006
- Meets ANSI Standard C62.41-1991
- · Meets FCC Part 18C for EMI & RFI (non-consumer)
- · EOL Protection

Application:

- · IDTP "tap" Function: Provides 120V to heaters of IDTPs.
- Compatible with 3 or 4 wire IDTPs
- Operation with IDTP is dual voltage rated for 120V or 277V.
- Can be operated as normal HID ballast with tap lead capped-off for entire 120V to 277V input voltage range

188633

- Minimum Starting Temperature: -15°C/+5°F
- 80°C/176°F · Maximum Case Temperature:
- · Sound Rated:
- · Remote Mounting:

Safety:

No PCBs

- _cUL_{US} Listed (Outdoor Type 1)
- Thermal Protection

Physical Parameters

· Overall Length:

Inches/Metric						
5.02"/127.5mm						
3.62"/92.0mm						
1.57"/39.9mm						

- · Height:
- Weight:

· Width:

- · Lead lengths: All • Lead stripping:(Tinned) All

20.07 7"/178mm .375"/9.53mm

15 Feet Note: Each lamp's lead wires must be run in a separate minimum 1/2" ID conduit from the input leads to achive good EMI performance and maximum remote capabilities. Individual , unbundled lead wires must be used for extension wiring using wire types SF-2 or SFF-2 or equivalent. Power cords and MC cables are not acceptable extension wiring methods.

Warranty:

Universal Lighting Technologies warrants to the purchaser that each electronic ballast will be free from defects in material or workmanship for a period of 3 years from date of manufacture when properly installed and under normal conditions of use. The normal operation of 4000 hr./yr. is used for the warranty period. Longer operating times will adjust the warranty period accordingly. For extended warranty periods greater than 36 months, call 1-800 BALLAST for fixture testing instructions.

Α

