369280h 1 09.04.12

#### Hi-lume® 3D Overview

Hi-lume® 3D architectural electronic dimming ballasts are designed to meet the most demanding lighting requirements. By providing industry leading performance with a full-range of 100% to less than 1% fluorescent dimming, Hi-lume® 3D ballasts enable you to provide the ideal visual environment for any application.

#### **Features**

- Continuous, flicker-free dimming from 100% to 0.7% for T8, 1% for T5 and T5HO, and 5% for T5 twin-tube
- 100% compatible with all Lutron® 3-wire fluorescent controls and EcoSystem® digital controls for consistent fixture-to-fixture dimming performance
- Compatible with Energi Savr Node™ with EcoSystem® devices, GRAFIK Eye® QS control unit, PowPak™ dimming module with EcoSystem® connection, and Quantum® software, allowing for integration into an existing or planned EcoSystem® lighting control solution.
- Programmed rapid start design preheats lamp cathodes before applying full arc voltage to ensure full-rated lamp life while dimming and cycling
- Lamps turn on to any dimmed level without going to full brightness
- Low harmonic distortion throughout the entire dimming range maintains power quality
- Frequency of operation ensures that ballast does not interfere with infrared devices operating between 38 kHz and 42 kHz
- Inrush current limiting circuitry eliminates circuit breaker tripping, switch arcing, and relay failure
- Ballasts maintain consistent light output for different lamp lengths, ensuring fixture-to-fixture uniformity
- Ultra-quiet operation
- Ballast protected from miswires of any input power to control lead, or from lamp leads to each other and/or ground



Hi-lume<sub>®</sub> 3D, case type C 1.18 in (30 mm) W x 1.00 in (25 mm) H x 18.00 in (457 mm) L



**Hi-lume**<sub>®</sub> **3D, case type G** 2.38 in (60 mm) W x 1.00 in (25 mm) H x 9.50 in (241 mm) L

- 100% performance tested and burned in at factory
- Non-volatile memory restores all ballast settings after power failure
- Buy American Act (BAA) models available; see Model List for specific availability
- RoHS compliant
- NOM certified models available; see Model List for specific availability
- Custom ballast factors available for UL or CSA listed products. Design tool and specifications can be found at www.lutron.com/ballasttool

<b>\$LUTRON</b> ®	SPECIFICATION	SUBMITTAL
-------------------	---------------	-----------

Job Name:	Model Numbers:
Job Number:	

369280h 2 09.04.12

# **Specifications**

#### **Regulatory Approvals**

- California Energy Commission Listed \*
- UL Listed (evaluated to the requirements of UL935)
- CSA certified (evaluated to the requirements of C22.2 No. 74) (specific model numbers only)
- Class P thermally protected
- Meets ANSI C82.11 High Frequency Ballast Standard
- Meets FCC Part 18 Non-Consumer requirements for EMI/RFI emissions
- Meets ANSI C62.41 Category A surge protection standards up to and including 4 kV
- Manufacturing facilities employ ESD reduction practices that comply with the requirements of ANSI/ESD S20.20
- Lutron<sub>®</sub> Quality Systems registered to ISO9001.2008

#### Environment

- Minimum lamp starting temperature: 50 °F (10 °C)
- Relative humidity: less than 90% non-condensing
- Sound Rating: Class A
- Maximum ballast case temperature: 75 °C

#### **Ballast Wiring & Mounting**

- Ballast is grounded via a mounting screw to the fixture
- Ballast mounts using two screws (or sheet metal feature and one screw) within a fluorescent fixture.
- Power and lamp wiring terminals accept one 18 to 16 AWG (0.75 to 1.5 mm²) solid copper wire per terminal.

#### **Lamp Seasoning**

 Refer to the lamp manufacturer's requirements for lamp seasoning requirements prior to dimming.

#### Warranty

 5-year limited warranty with Lutron® field service commissioning (3-year standard warranty) from date of purchase. For additional Warranty information, please visit: www.lutron.com/TechnicalDocumentLibrary/Ballast%20 and%20Driver%20Warranty.pdf

#### Performance

- Dimming Range: 100% to 0.7% measured relative light output (RLO) for T8, 100% to 1% measured RLO for T5 and T5HO, and 100% to 5% measured RLO for T5 twin-tube.
- Lamp Starting: programmed rapid start
- Lamp Current Crest Factor: less than 1.7
- Lamp Flicker: none visible
- Light Output Variation: constant ±2% light output for line voltage variations of ±10%
- Lamp Life: average lamp life meets or exceeds rating of lamp manufacturer
- Power Factor: greater than 0.95
- Typical Total Harmonic Distortion (THD) less than 10%\*\*
- Maximum Inrush Current: 7 A per ballast at 120 V ∼ 3 A per ballast at 277 V ∼
- Operating Voltage: Universal input 120, 220/240, 277 V∼ at 50/60 Hz
- Frequency of Operation: greater than 42 KHz
- Ballast Factor (BF): 1.0/1.17 for T8 lamps and 1.0 for T5, T5HO, and T5 twin-tube lamps

#### Dimming Range for T5 and T5HO lamps:

BF	Dimming Range (Max/Min [BF])	Dimming Ratio
1.0	1.00 / 0.01	100:1

#### Dimming Range for T8 lamps:

BF	Dimming Range (Max/Min [BF])	Dimming Ratio
1.17	1.17 / 0.0085	138:1
1.0	1.00 / 0.0085	118:1

#### Dimming Range for T5 Twin Tube lamps:

BF	Dimming Range (Max/Min [BF])	Dimming Ratio
1.0	1.00 / 0.05	100:5

- \* Not required for T5 twin tube models.
- \*\* Typical THD for models H3DT817CU110, H3DT514CU110 and H3DT521CU110 less than 15%.

#### **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369280h 7 09.04.12

# Hi-lume<sub>®</sub> 3D Ballasts for Twin-Tube T5 Lamps

Not for use with Reduced Wattage Lamps

Lamp Type	Lamp Watts (length)	Lamps per Ballast	Case Size	Hi-lume⊚ 3D Model Number	_	Ballast Current (A)	Ballast Factor (BF)	Input Power (W)	System Lumens <sup>2</sup> (Im)	System Efficacy <sup>2</sup> (Im/W)	Ballast Efficacy Factor (BEF)	Relative System Efficacy (RSE)
T5 Twin- Tube	50 W (22.5 in [572 mm])	1	G	H3D T550 G U 1 10 <sup>1</sup>	120 240 277	0.45 0.23 0.20	1.00 1.00 1.00	53.5 54.6 54.8	4000 4000 4000	75 73 73	1.87 1.83 1.82	0.93 0.92 0.91
	D	2	G	H3D T550 G U 2 10 <sup>1</sup>	120 240 277	0.84 0.42 0.36	1.00 1.00 1.00	99.8 99.8 98.7	8000 8000 8000	80 80 81	1.00 1.00 1.01	1.00 1.00 1.01
	40 W (22.5 in [572 mm])	1	G	H3D T540 G U 1 10 <sup>1</sup>	120 240 277	0.36 0.18 0.16	1.00 1.00 1.00	42.8 42.8 43.9	3100 3100 3100	72 72 71	2.34 2.34 2.28	0.93 0.93 0.91
		2	G	H3D T540 G U 2 10 <sup>1</sup>	120 240 277	0.64 0.32 0.27	1.00 1.00 1.00	76.0 76.0 74.0	6200 6200 6200	82 82 84	1.32 1.32 1.35	1.05 1.05 1.08
		3	G	H3D T540 G U 3 10 <sup>1</sup>	120 240 277	0.95 0.47 0.40	1.00 1.00 1.00	112.9 111.7 109.7	9300 9300 9300	82 83 85	0.89 0.90 0.91	1.06 1.07 1.09
	36 W (15.5 in [394 mm])	1	G	H3D T536 G U 1 10 <sup>1</sup>	120 240 277	0.33 0.17 0.14	1.00 1.00 1.00	39.2 40.4 38.4	2850 2850 2850	73 71 74	2.55 2.48 2.60	1.02 0.99 1.04
		2	G	H3D T536 G U 2 10 <sup>1</sup>	120 240 277	0.61 0.31 0.26	1.00 1.00 1.00	72.5 73.7 71.3	5700 5700 5700	89 77 70	1.38 1.36 1.40	1.10 1.09 1.12

#### Notes:

#### **ELUTRON** SPECIFICATION SUBMITTAL


<b>LUTRON</b> ® SPECIFI	Page	
Job Name:	Model Numbers:	
Job Number:		

<sup>1.</sup> NOM approved models available. Add a "N" to suffix of model number when ordering (ie: H3D T832 C U 1 10N).

<sup>2.</sup> Actual number may vary with lamp model. Please consult lamp manufacturer for lamp-specific data.


# **Case Dimensions**


# C



- 18.00 in (457 mm)
  - 17.68 in (449 mm) (mounting center)
  - 1.0 in (25 mm)
- D 1.18 in (30 mm)

# G





- A 9.5 in (241 mm)
- B 8.9 in (226 mm) (mounting centers)
- C 7.1 in (180 mm)
- D 1.0 in (25 mm)
- E 2.38 in (60 mm)

# **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369280h 9 09.04.12

# Hi-lume<sub>®</sub> 3D Dimmer Wiring

#### 3-Wire Control Wiring



WARNING: Shock hazard. May result in serious injury or death. Disconnect power before servicing or installing.

- Make sure that the supply breaker to the Digital Ballast is OFF when wiring
- Wire as shown


Line input:	Connects to:		
Hot	Dimmer Black Wire		
Neutral	Dimmer White Wire		

Dimmer wire:	Connects to:
Yellow	Ballast Orange (DH)
Red	Ballast Black (HOT)
White	Ballast White (NEU)
Green	Earth Ground

• Hi-lume® 3D ballast line voltage and 3-wire input terminals accept one 18 to 16 AWG (0.75 to 1.5 mm²) solid copper wire per terminal.

## **Emergency**

• For emergency wiring please see Lutron® App Note #106.



## **ELUTRON** SPECIFICATION SUBMITTAL

<b>LUTRON</b> ® SPECIFICATIO	Page	
Job Name:	Model Numbers:	
Job Number:		

369280h 10 09.04.12


# Hi-lume<sub>®</sub> 3D Wiring Diagrams

#### EcoSystem® Digital Link Overview

- The EcoSystem® Digital Link wiring (E1 and E2)
   connects digital ballasts and drivers together to form a
   lighting control system.
- Sensors do not directly connect to Hi-lume® 3D ballasts.
- E1 and E2 (EcoSystem<sub>®</sub> digital link wires) are polarity insensitive and can be wired in any topology.
- An Energi Savr Node™ with EcoSystem® unit, GRAFIK Eye® QS control unit with EcoSystem®, or Quantum® dimming module with EcoSystem® provides power for the EcoSystem® digital link which supports up to 64 digital ballasts or LED drivers, 64 occupant sensors, 16 daylight sensors and 64 wall stations or IR receivers.
- PowPak™ dimming module with EcoSystem® provides power for the EcoSystem® digital link which supports up to 32 digital ballasts or LED drivers, 6 occupant sensors, 1 daylight sensor and 9 Pico® wireless controllers.
- All EcoSystem® Digital Link programming is completed by using the Energi Savr App for an Apple iPad, iPod Touch or iPhone mobile digital device; GRAFIK Eye® QS with EcoSystem®, PowPak™ dimming module with EcoSystem®; or Quantum® System.
- For complete information, see EcoSystem® Design & Application Guide (P/N 367-1533).
- For emergency wiring please see Lutron<sub>®</sub> App Note #106.

### EcoSystem® Digital Link Wiring

- Ballast EcoSystem® Digital Link terminals accept one 18 to 16 AWG (0.75 to 1.5 mm²) solid copper wire per terminal.
- Make sure that the supply breaker to the Digital Ballast and EcoSystem® Digital Link Supply is OFF when wiring.
- Connect the two conductors to the two Digital Ballast terminals E1 and E2 as shown.
- Using two different colors for E1 and E2 will reduce confusion when wiring several ballasts together.



To the EcoSystem® Digital Link Supply

 The EcoSystem® Digital Link may be wired Class 1 or Class 2. Consult applicable electrical codes for proper wiring practices.

#### **Notes**

- The EcoSystem® Digital Link Supply does not have to be located at the end of the Digital Link.
- EcoSystem® Digital Link length is limited by the wire gauge used for E1 and E2 as follows:

Wire Gauge	Maximum		
	Digital Link Length		
12 AWG	2200 ft		
14 AWG	1400 ft		
16 AWG	900 ft		
18 AWG	550 ft		

Wire Size	Maximum Digital Link Length	
4.0 mm <sup>2</sup>	825 m	
2.5 mm <sup>2</sup>	515 m	
1.5 mm <sup>2</sup>	310 m	
1.0 mm <sup>2</sup>	205 m	
0.75 mm <sup>2</sup>	155 m	

Apple, iPad and iPhone are trademarks of Apple Inc., registered in the U.S. and other countries.


### **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369280h 11 09.04.12

# Hi-lume<sub>®</sub> 3D Ballast Wiring Diagrams — T8, T5, and T5HO linear lamps

Wiring to One Lamp (C case shown)



## Wiring to Two Lamps (C case shown)



#### **NOTICE**

- Maximum ballast to lamp socket lead length is 7 ft (2 m)
- Wire colors shown are labeled on the ballast, but may vary depending upon fixture construction


#### **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369280h 12 09.04.12

# Hi-lume<sub>®</sub> 3D Ballast Wiring Diagrams — T8, T5, and T5HO linear lamps


## Wiring to One Lamp (G case shown)



#### Wiring to Two Lamps (G case shown)



# Wiring to Three Lamps (G case shown)



#### **NOTICE**

- Maximum ballast to lamp socket lead length is 7 ft (2 m)
- Wire colors shown are labeled on the ballast, but may vary depending upon fixture construction


# **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369280h 13 09.04.12

# Hi-lume<sub>®</sub> 3D Ballast Wiring Diagrams — T5 Twin-Tube


## Wiring to One Lamp



## Wiring to Two Lamps



# Wiring to Three Lamps



## **NOTICE**

- Maximum ballast to lamp socket lead length is 3 ft (1 m)
- Wire colors shown are labeled on the ballast, but may vary depending upon fixture construction

## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369280h 14 09.04.12

# ATTENTION ELECTRICIANS AND CONTRACTORS

#### **Ballast/Socket Leads**

Lead lengths from ballast to socket must not exceed 7 ft (2 m) for T8, T5, and T5HO linear lamps.

#### **Lamp Sockets**

Lutron requires and NEMA® recommends sockets complying with IEC 60400. Inspect sockets for marks to ensure the socket complies with IEC 60400. Two examples of these marks are: 45 and 65. Sockets **must** have a 60 mark as well. Use Rapid Start sockets.

**DO NOT** use Instant Start sockets. See Lutron<sub>®</sub> App Note #122 or NEMA<sub>®</sub> doc LSD-34-2006.


#### **Lamp Socket Wiring Tester**

Use Socket Tester (FDB-LSWT-T5/T8) to verify proper lamp holder wiring.

Available for purchase at www.lutronstore.com

## **Lamp Mounting**

Many fluorescent lamp sockets are available with mounting slots to vary the height of the lamp away from the grounded metal surface. Having a fluorescent lamp too close to the grounded metal will reduce lamp life. Having a fluorescent lamp too far away from the grounded metal will make the lamp flicker or not turn on at all. Please note that all of the lamp heights are measured between the grounded metal surface and the glass wall of the lamp.



**IMPORTANT:** Lamps must never touch ground plane and should be placed without obstruction.

#### Mounting for T8 Lamps

Mount lamps 1/8 to 3/4 in (3.2 to 19 mm) away from the grounded metal surface.

#### Mounting for T5 and T5HO Lamps

Mount lamps 1/16 to 3/8 in (1.6 to 9.5 mm) away from the grounded metal surface.

#### Mounting for T5 Twin Tube Lamps

Mount lamps 1/16 to 1/2 in (1.6 to 13 mm) away from the grounded metal surface.

#### **Ballast Operating Temperature**

Ballast case temperature must not exceed 75 °C at any point on the ballast.

#### Cold Air Flow

Ensure that no cold air (from HVAC system, etc) is blowing across the lamps. Cooling the lamp will cause performance issues as noted in NEMA LSD-34.

#### Wiring and Grounding

Ballast and lighting fixture must be effectively grounded. Ballasts must be installed per national and local electrical codes.

# ATTENTION FACILITIES MANAGERS

#### PERFORMANCE

#### Lamp Seasoning

Consult lamp manufacturer's recommendations on lamp seasoning prior to dimming.

#### **SERVICE**

#### Replacement Parts

Use Lutron® replacement parts with exact model numbers. Consult Lutron if you have any questions.

#### **Further Information**

For further information, please visit us at www.lutron.com/ballasts or contact our 24-hour Technical Support Center at 1.800.523.9466.

#### **STUTRON** SPECIFICATION SUBMITTAL

WEST TOTAL		1 agc
Job Name:	Model Numbers:	
Job Number:		