

IESNA LM-79: 2008

Measurement and Test Report

for

Green Creative Ltd.

Room 1206-7, New Victory House, 93-103 Wing Lok Street, Central, HONG KONG

Nov 06, 2013

Product Name:	LED 4" can retrofit kit
Model No:	11DL4G3DIM/827
Test Engineer:	David Zhang 
Report No.:	BTR66.181.13.1492.27
Sample Received Date:	Nov 01, 2013
Test Performed Date:	Nov 01, 2013 to Nov 05, 2013
Reviewed By:	Steven Hsu 
Prepared By:	BEST Test Service Shenzhen Co., Ltd. 1st Floor, 1st Building, Weitai Industrial Park, Yingrenshi, Shiyan, Baoan, Shenzhen, China TEL: +86-755-28236006 FAX: +86-755-23467087-811 Email: certification@bestcert.cn



Note: The test report only allows to be revised within the retention period unless further standard or the requirement was noticed. This report is for the exclusive use of BEST's Client and is provided pursuant to the agreement between BEST and its Client. BEST's responsibility and Liability are limited to the terms and conditions of the agreement. BEST assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the BEST name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by BEST. The observations and test results in this report are relevant only to the sample tested. This report by itself does not cover that the material, product, of service is or has ever been under a BEST certification program. National Voluntary Laboratory Accreditation Program (NVLAP) has accredited this laboratory under ISO17025: 2005 for specific laboratory activities as listed in the NVLAP directory of accredited laboratories. The results shown in this report were determined by this laboratory in accordance with its terms of accreditation.

TABLE OF CONTENTS

1 - GENERAL INFORMATION.....3

- 1.1 PRODUCT DESCRIPTION FOR EQUIPMENT UNDER TEST (EUT)3
- 1.2 OBJECTIVE3
- 1.3 TEST FACILITY DESCRIPTION.....4
- 1.4 TEST EQUIPMENT LIST4

2 - TEST METHOD.....5

- 2.1 PHOTOMETRIC AND ELECTRICAL MEASUREMENT (INTEGRATED SPHERE METHOD)5
- 2.2 PHOTOMETRIC AND ELECTRICAL MEASUREMENT (GONIOPHOTOMETER METHOD)5
- 2.3 DEVIATION FROM STANDARD OPERATING PROCEDURE5

3 – SUMMARY OF TEST RESULT6

4 – SPECTRAL FLUX PLOTS8

5 – EUT PHOTOS.....9

6 – LUMINOUS INTENSITY DISTRIBUTION TEST PLOTS (CIE CHROMATICITY).....10



1 - GENERAL INFORMATION

1.1 Product Description for Equipment under Test (EUT)

Applicant	: Green Creative Ltd.
Product Name	: LED 4" can retrofit kit
Model No	: 11DL4G3DIM/827
Brand	: GREEN CREATIVE
SKU	: T.B.D
12 NC Code	: T.B.D
Nominal Operation Voltage	: AC 120V/60Hz
Nominal Power	: 11W
Nominal CCT	: 2700K
Nominal CRI	: 83
Nominal Lumen Output	: 640Lumens
Nominal Life Time	: 35000Hours
Number of hours operated prior to measurement for new sample	: 0 Hours
Stabilization Time	: 1.5 hours
Total operating time for measurement include stabilization time	: 3.5 hours
Date of Receiving Sample	: Nov 01, 2013
Measurement quantities measured	: 1 pcs
Orientation During Testing	: Horizontal
Test Requested	: Electrical and Photometric Test Luminous Intensity Distribution Test

1.2 Objective

The following test report is prepared on behalf of Green Creative Ltd. in accordance with IESNA LM-79-08, used the following American National Standards or illumination Engineering Society of North America test guides:

ANSI C78.377-2008: Specifications for the Chromaticity of Solid State Lighting Products;

ANSI C79.1– 2002: American National Standard for Electric Lamps – Nomenclature for Glass Bulbs Intended for Use with Electric Lamps;

ANSI C78.20 – 2003: American National Standard for Electric Lamps – A, G, PS, and Similar Shapes with E26 Medium Screw Bases;

ANSI C78.21 – 2011: American National Standard for Electric Lamps – PAR and R Shapes;

ANSI C78.24 – 2001: American National Standard for Electric Lamps – Two-inch (51 mm);

Integral-reflector Lamps with Front Covers and GU5.3 or GX 5.3 Bases;

ANSI/IEC C81.61-2003: American National Standard for Electric Lamp Bases;

ANSI/IEEE C62.41 – 1991 (01-May-1991): Surge Voltages in Low-Voltage AC Power Circuits, Recommended Practice for;

CIE Publication No. 13.3 – 1995: Method of Measuring and Specifying Color Rendering of Light Sources;

CIE Publication No. 18.2 – 1983: The Basis of Physical Photometry;

IESNA LM-16-1993: Practical Guide to Colorimetry of Light Sources;

IESNA LM-28-89 – 1989: Guide for the Selection, Care, and Use of Electrical Instruments in the Photometric Laboratory;

IESNA LM-79-08 Electrical and Photometric Measurement of Solid State Lighting Products

UL 1993 – 1999: Standard for Self-Ballasted Lamps and Lamp Adapters;

UL 8750 – 2009: Light Emitting Diode (LED) Equipment for Use in Lighting Products.

1.3 Test Facility Description

The Energy Efficiency Lab used by BEST to collect energy efficiency measurement data is located in 1st Floor, 1st Building, Weitai Industrial Park, Yingrenshi, Shiyao, Baoan, Shenzhen, China. BEST Test Service Shenzhen Co., Ltd is a National Institute of Standards and Technology (NIST) accredited laboratory, under the National Voluntary Laboratory Accredited Program (Lab Code 200770-0). BEST Test Service Shenzhen Co., Ltd is also an ELI accredited lab for lighting products (ELI Certificate No. ELI-L04-2010) and UL accredited lab for lighting products

1.4 Test Equipment List

Apparatus List	Device	Cal. Date	Cal Due Date
1	Integral Sphere+ Spectrophotometer System	Mar 10, 2013	Mar 09, 2014
2	Digital Power Meter	Oct 18, 2013	Oct 17, 2014
3	Goniophotometer+ Spectrophotometer System	Nov 20, 2012	Nov 19, 2013
4	Standard Light Source	Sep 17, 2013	Sep 16, 2014
5	Standard Light Source	Sep 17, 2013	Sep 16, 2014
6	Digital Storage Oscilloscope	Oct 18, 2013	Oct 17, 2014
7	Ultra Compact Simulator	Oct 20, 2013	Oct 20, 2014
8	Temperature Chamber	Oct 20, 2013	Oct 20, 2014
9	Digital Caliper	Nov 20, 2012	Nov 19, 2013
10	Digital CC&CV DC Power Supply(30V 5A)	N/A	N/A
11	5 1/2 Digital Multimeter	Oct 18, 2013	Oct 17, 2014
12	Digital CC&CV DC Power Supply(120V 10A)	N/A	N/A
13	6 1/2 Digital Multimeter	Oct 18, 2013	Oct 17, 2014
14	Digital Multimeter	Oct 18, 2013	Oct 17, 2014
15	Temperature Recorder+Thermocouple	Nov 20, 2012	Nov 19, 2013
16	Timer Controller	Nov 20, 2012	Nov 19, 2013

Statement of Traceability: BEST Test Service Shenzhen Co., Ltd. certifies that all calibration has been performed using suitable standards traceable to the NIM China.

2 - Test Method

2.1 Photometric and Electrical Measurement (Integrated Sphere Method)

Total light output (luminous flux) for the $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$ ambient temperature conditions is measured using a 1.6m Φ geometry integrating sphere. Temperature is measured at a position inside the sphere. Spectral radiant flux measurements are made using Lab sphere to the detector port of the integrating sphere. Each lamp is operated at rated voltage in its designated orientation. Each lamp should be stable before measurements are made. The determining method of stable is as follows:

Step 1 Take 3 measurements of the lamp light output at 15 minute interval (total time=30mintues.)This time period is in addition to the recommended pre-burning time.

Step 2 Calculate the percent difference between the maximum measured value and the minimum measured value for the three consecutive measurements.

Step 3 if the value calculated in Step 2 does not exceed 0.5 percent, the lamp is considered stable. Luminous flux, chromaticity coordinates, correlated color temperature and color rendering index for each lamp are calculated from the spectral radiant flux measurements taken at 2 nm intervals over the range 350 to 1050 nm. The calibration of the sphere photometer-spectrometer system is traceable to the NIST USA. Lamp efficacy (lumens per watts) for each lamp model is computed based on the revised luminous flux result. Electrical measurements including voltage, current, power and power factor are measured using the digital power Meter.

The total uncertainty of the light output measurements is estimated, at the 95% confidence level, not to exceed $\pm 1.12\%$ over the wavelength range 350-1050 nm.

2.2 Photometric and Electrical Measurement (GonioPhotometer Method)

A Goniometer was used to measure the intensity (candelas) at each angle of distribution for each sample; the photometric distance is 24m. Ambient temperature was measured equal to the height of the sample mounted on the Goniometer equipment. Each sample was operated at input rated voltage in its designated orientation. Each sample was allowed to be stable before measurement was made. Electrical measurements including voltage, current, power and power factor were measured using the Power Analyzer

Before each measurement, the method below should be used to determine the lamp is stable or not.

Step 1 Take 3 measurements of the lamp intensity at 15 minute interval (total time=30mintues.)This time period is in addition to the recommended pre-burning time.

Step 2 Calculate the percent difference between the maximum measured value and the minimum measured value for the three consecutive measurements.

Step 3 if the value calculated in Step 2 does not exceed 0.5 percent, the lamp is considered stable.

Some graphics were created with Photometric Plus software.

2.3 Deviation from standard operating procedure

None.

3 – Summary of Test Result


	Item	Test Result		Accreditation
Required Fields	Lumen Output (Lumens)	699.45		NVLAP/EPA
	Luminous Efficacy (lm/w)	66.26		NVLAP/EPA
	Correlated Color Temperature (CCT)	2697		NVLAP/EPA
	Color Rendering Index– CRI	84.1		NVLAP/EPA
	Input Power (W)	10.56		NVLAP/EPA
Optional Fields	Power Type	<input checked="" type="checkbox"/> AC	<input type="checkbox"/> DC	/
	Input Voltage (V)	120.0		NVLAP/EPA
	Input Current (A)	0.0881		NVLAP/EPA
	Power Factor	0.9980		NVLAP/EPA
	x(CIE 1931)	0.4612		NVLAP/EPA
	y(CIE 1931)	0.4126		NVLAP/EPA
	u' (CIE 1976)	0.2624		NVLAP/EPA
	v' (CIE 1976)	0.5283		NVLAP/EPA
	Duv(CIE 1976)	0.0006		NVLAP/EPA
	Beam Angle: (Degree)	88.0		NVLAP/EPA
	Center beam candlepower: (cd)	329		NVLAP/EPA
	Zonal lumen density (0-60°):	84.9%		NVLAP/EPA
	Zonal lumen density (60-90°):	15.1%		NVLAP/EPA
	Zonal lumen density (90-120°):	0%		NVLAP/EPA
Zonal lumen density (120-180°):	0%		NVLAP/EPA	

	CRI (R1)	82	NVLAP/EPA
	CRI (R2)	90	NVLAP/EPA
	CRI (R3)	97	NVLAP/EPA
	CRI (R4)	82	NVLAP/EPA
	CRI (R5)	81	NVLAP/EPA
	CRI (R6)	87	NVLAP/EPA
	CRI (R7)	86	NVLAP/EPA
	CRI (R8)	66	NVLAP/EPA
	CRI (R9)	25	NVLAP/EPA
	CRI (R10)	77	NVLAP/EPA
	CRI (R11)	80	NVLAP/EPA
	CRI (R12)	70	NVLAP/EPA
	CRI (R13)	84	NVLAP/EPA
	CRI (R14)	98	NVLAP/EPA

Lumen summary:

[OTHER]	Gamma(deg)	Fz(lm)	Ft(lm)	%Lum	%Lamp
[OTHER]	0- 10	30.88	30.88	4.41	4.41
[OTHER]	10- 20	85.59	116.46	16.65	16.65
[OTHER]	20- 30	121.44	237.91	34.01	34.01
[OTHER]	30- 40	133.05	370.96	53.04	53.04
[OTHER]	40- 50	123.21	494.17	70.65	70.65
[OTHER]	50- 60	99.42	593.58	84.86	84.86
[OTHER]	60- 70	68.58	662.17	94.67	94.67
[OTHER]	70- 80	32.60	694.77	99.33	99.33
[OTHER]	80- 90	4.68	699.45	100.00	100.00
[OTHER]	90-100	0.00	699.45	100.00	100.00
[OTHER]	100-110	0.00	699.45	100.00	100.00
[OTHER]	110-120	0.00	699.45	100.00	100.00
[OTHER]	120-130	0.00	699.45	100.00	100.00
[OTHER]	130-140	0.00	699.45	100.00	100.00
[OTHER]	140-150	0.00	699.45	100.00	100.00
[OTHER]	150-160	0.00	699.45	100.00	100.00
[OTHER]	160-170	0.00	699.45	100.00	100.00
[OTHER]	170-180	0.00	699.45	100.00	100.00

4 – Spectral Flux Plots




5 – EUT Photos



6 – Luminous Intensity Distribution Test Plots (CIE Chromaticity)

LAMP PHOTOMETRIC REPORT

Electrical: Voltage:120.0V Current:0.0881A Power:10.56W Factor:0.9980		
MODEL: 11DL4G3DIM/827		
POWER: 11W	VOLTAGE: 120.0V	WORKING VOLTAGE: 120.0V
MANUFACTURER: Green Creative		Eff.: 66.26 lm/W



γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	φ zone	φ total	%
10	314.9	318.2	321.2	322.3	321.1	317.6	314.2	313.4	0- 10	30.88	30.88	4.41
20	281.1	286.9	292.2	294.4	292.6	285.8	279.1	278.1	10- 20	85.59	116.5	16.7
30	233.3	240.5	246.9	249.7	247.9	239.0	229.8	228.9	20- 30	121.4	237.9	34
40	179.8	187.1	193.7	196.4	194.5	185.5	175.7	175.2	30- 40	133.1	371.0	53
50	128.8	135.3	141.3	143.6	142.0	134.3	125.3	125.0	40- 50	123.2	494.2	70.7
60	84.40	89.83	94.83	96.82	95.71	89.24	81.88	81.45	50- 60	99.42	593.6	84.9
70	45.10	49.93	54.78	56.61	55.09	49.65	43.66	42.71	60- 70	68.58	662.2	94.7
80	10.38	13.96	17.58	18.96	17.70	13.69	9.888	9.003	70- 80	32.60	694.8	99.3
90	0	0.0033	0.1901	0.2869	0.1978	0	0	0	80- 90	4.676	699.4	100
100	0	0	0	0	0	0	0	0	90-100	0.0049	699.5	100
110	0	0	0	0	0	0	0	0	100-110	0.0000	699.5	100
120	0	0	0	0	0	0	0	0	110-120	0	699.5	100
130	0	0	0	0	0	0	0	0	120-130	0	699.5	100
140	0	0	0	0	0	0	0	0	130-140	0	699.5	100
150	0	0	0	0	0	0	0	0	140-150	0	699.5	100
160	0	0	0	0	0	0	0	0	150-160	0	699.5	100
170	0	0	0	0	0	0	0	0	160-170	0	699.5	100
180	0	0	0	0	0	0	0	0	170-180	0	699.5	100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:David

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.287
 Humidity:62.7%
 Test Distance:2.463m [K=1.0000]

LUMINOUS DISTRIBUTION INTENSITY DATA

Electrical: Voltage:120.0V Current:0.0881A Power:10.56W Factor:0.9980		
MODEL: 11DL4G3DIM/827		
POWER: 11W	VOLTAGE: 120.0V	WORKING VOLTAGE: 120.0V
MANUFACTURER: Green Creative		Eff.: 66.26 lm/W

Table--1

UNIT: cd

C (DEG) γ (DEG)	0	23	45	68	90	113	135	158	180	203	225	248	270	293	315	338			
0	329	329	329	329	329	329	329	329	329	329	329	329	329	329	329	329			
5	325	325	326	327	328	329	329	328	328	327	326	325	324	324	324	324			
10	315	317	318	320	321	322	322	322	321	319	318	316	314	313	313	314			
15	300	303	305	307	309	310	311	310	309	307	304	301	299	298	298	299			
20	281	284	287	290	292	294	294	294	293	290	286	282	279	278	278	280			
25	258	262	265	268	271	273	274	273	272	268	264	259	256	254	255	257			
30	233	237	241	244	247	249	250	249	248	244	239	234	230	228	229	231			
35	207	210	214	218	221	223	224	223	222	218	212	207	203	201	202	205			
40	180	183	187	191	194	196	196	196	195	191	185	180	176	174	175	178			
45	154	157	161	164	167	169	169	169	168	164	159	154	150	148	149	152			
50	129	132	135	139	141	143	144	143	142	139	134	129	125	124	125	127			
55	106	109	112	115	117	119	119	119	118	115	111	106	103	101	102	105			
60	84.4	87.0	89.8	92.5	94.8	96.3	96.8	96.2	95.7	92.9	89.2	85.1	81.9	80.7	81.5	83.4			
65	64.8	67.2	69.8	72.4	74.4	75.8	76.3	75.6	75.1	72.6	69.3	65.6	62.8	61.6	62.2	63.8			
70	45.1	47.4	49.9	52.5	54.8	56.3	56.6	55.8	55.1	52.7	49.7	46.3	43.7	42.4	42.7	44.1			
75	26.3	28.4	30.7	33.1	35.2	36.5	36.8	36.1	35.4	33.2	30.4	27.6	25.4	24.2	24.3	25.4			
80	10.4	12.1	14.0	15.9	17.6	18.7	19.0	18.3	17.7	16.0	13.7	11.7	9.89	9.06	9.00	9.70			
85	1.08	1.68	2.53	3.93	4.61	5.22	5.60	5.02	4.44	3.34	2.27	1.47	1.02	0.83	0.80	0.94			
90	0.00	0.00	0.00	0.05	0.19	0.27	0.29	0.24	0.20	0.05	0.00	0.00	0.00	0.00	0.00	0.00			
95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
105	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
115	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
125	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
135	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
140	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
145	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
155	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
160	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
165	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
170	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
175	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
180	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:David

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.287
 Humidity:62.7%
 Test Distance:2.463m [K=1.0000]