



Titanium Series T8 15W, 12W, 8W DIR
 For models: 15T8/4F/xxx/DIR, 12T8/4F/xxx/DIR, 8T8/2F/xxx/DIR
 Where xxx means 824-965 which indicates CRI and color temperature

0-10V Dimmability

| Brand | Model Number | Ballast | | | |
|---------|--------------|---------------|------------|-------------|----------------|
| | | Philips | | | GE |
| | | IZT-2PSP32-SC | IZT-132-SC | ILV-2S32-SC | GE232MVPSN-V03 |
| Lutron | DVTV | OK w/Noise | OK | OK | OK |
| Cooper | SF10P | OK w/Noise | OK | OK | OK |
| Leviton | IP710-DL | OK w/Noise | OK | OK | OK |
| Legrand | H4FBL3P | OK w/Noise | OK | OK | OK |

Triac 120V Dimmability

| Brand | Model Number | Ballast |
|---------|--------------|-----------------|
| | | Philips |
| | | REZ-2S32-SC |
| Lutron | TGCL-153P | OK |
| | D-603PG | 100-20% |
| | MA-600 | X |
| | DV-600PR | 100-50%, 20-10% |
| | CTCL-153P | 100-50%, 25-10% |
| | TG-600PR | 100-50%, 20-10% |
| | DVCL-153P | 100-50%, 20-10% |
| | AYCL-153P | 100-50%, 20-10% |
| | D-600R | 100-20% |
| | D-600PR | 100-50%, 20-10% |
| | CT-600PR | 100-50%, 25-10% |
| Cooper | 9540 | 100-50%, 20-10% |
| Leviton | VP106 | X |
| | 6633 | 100-50%, 20-10% |
| | 6674 | 100-50%, 20-10% |

Triac 277V Dimmability

| Brand | Model Number | Ballast | |
|----------|-----------------------|-----------------|-----------------|
| | | Philips | |
| | | VEZ-132-SC | VEZ-2S32-SC |
| Leviton | VPX12 | 100-50%, 25-10% | 100-30% |
| Lithonia | ISD 1200 ADEZ 277 H10 | 100-50%, 25-10% | 100-50%, 25-10% |

*GREEN CREATIVE has provided this dimmer compatibility chart for guidance when selecting a ballast, dimmer and lamp combination. Lamps were tested for compatibility with the above listed ballasts and dimmers. Ballasts and dimmers that do not appear on the chart might still be compatible but have not been tested. All testing has been performed with a stable main supply. The quality of the local main, existing installation and wiring, as well as different manufacturer versions of the above ballasts may affect lamp performance. Since no assurance can be provided regarding these factors, it is a general recommendation to perform a test on-site prior to installing the LED lamps.