


INSTALLATION INSTRUCTIONS-TRACK

1. Place track over outlet box and mark position of track mounting holes on ceiling or wall. On wallboard or plaster, drill 5/8" mounting holes.
2. Plain underside of track faces ceiling or wall and slotted side of track faces out to accept lights.
3. Install track to ceiling or wall using toggle bolts (furnished). On wood surface use standard #10 wood screws (not furnished).

WARNING: Track is used only in ceiling or wall. If track is intended for use in being suspended from the ceiling, a qualified electrician is required. If track is suspended from the ceiling, Pendant Assembly Kit is required, and if track is suspended and joined with other tracks by connectors, I and L Strengthened Plate are required to reinforce the connection where track and connector join. Without using the I and L Strengthened Plate with Pendant Assembly Kit, there will be a risk of fire. After all tracks are connected, be sure to re-cover the connectors to avoid the risk of fire.



SAVE THESE INSTRUCTIONS

IMPORTANT SAFETY INSTRUCTION

When installing or using this track system, basic safety precautions should always be followed including the following :

1. Read all instructions.
2. Do not install this track in damp or wet locations.
3. (Unless provision for field cutting), Do not cut any track sections.
4. Do not install any part of a track system less than 5 feet above the floor.
5. Do not install any fixture assembly closer than 6 inches from any curtain, or similar, combustible material.
6. Disconnect electrical power before adding to or changing the configuration of the track.
7. Do not attempt to energize anything other than lighting track fixtures on the track. To reduce the risk of fire and electric shock, do not attempt to connect power tools, extension cords, appliances, and the like to the track.
8. (For track lighting system other than 120V, two-wire), Do not connect the track to more than one branch circuit unless the track is constructed so that it can be used with more than one branch circuit. Check with a qualified electrician. Although the track lighting system may seem to operate acceptably, a dangerous overload of the neutral may occur and result in a risk of fire.

SAVE THESE INSTRUCTIONS